

- Had Bob Northup up and put a lot of new points on our IAMGIS map.
- Land applied bio solids from the WWTP on October 28-29. Should be able to leave the blowers off in sludge holding tank for a few months. As soon as time allows we are planning on transferring basins from #2 to #1.
- No word out of First net for tower replacement.
- Had GMS move forward with the PNA for resort water plant. Received an email from Erica Countryman reaching out to a structural engineer to see when he would be available to look at the current structure at the resort.
- We will sample w and ww October 10. Todd was on vacation first week of the month so we will sample when he is back.
- Drury sent final bill for roof at WWTP. I sent it on to you all and Nella. Probably discuss during the meeting today.
- Had leak at Aspen condos 2x we assisted there maintenance guy and Tyler Huff's crew and got them put back together. We probably had 12 man hours and 2 hours on our backhoe. Seeking direction on whether we should bill Aspen Leaf?
- The guys continue to install meters every chance they get. We have put in around 18 or so since last board meeting.
- Glenn had a 1 year anniversary and Todd had 5 year anniversary recently. Shaylee also met the 90 day probation mark and glad to have her on board as well as Kristan hanging in there with us.
- The three service vehicles have oil changed in all of them and we put brakes and rotors on the front of the utility truck.
- All the filter media is her for the SPWTP and have been working on a time that a Filter Tech rep can come down and oversee media installation.
- Laveta Propane put new roof jacks and tuned up the heaters in the SPWTP so we shouldn't have any issues up there this winter.
- The state changed my MOR reporting requirements and by them doing that I am going to have a violation for October and November. The violation is a tier 2 which means we will have to do another mailing. I have worked with the state and believe we have a resolution on fixing the problem. I basically turned down the VFD'S on the raw water so it can sit in the chlorine contact chamber longer before it leaves the plant. *Jim Ait to review*
- I will be hit and miss a little in November do to Dr. appointments and my house arriving and needing everything to be hooked up and inspections and all. I will keep the board and staff informed of my schedule.

2021 -